



CIVIL QUALITY CONSULTANTS & ENGINEERS

(Buildings Geo-Tech & Highway Materials Testing Laboratory)

An ISO 9001: 2015 Certified Company

NABL Accredited As Per ISO/IEC : 17025:2005 Laboratory



Job No.: CQCE/BBMP/MY/W.No.12/2019-20

Date : 23.11.2019

TEST REPORT ON FINE AGGREGATES (SAND) IS 383-1970 (RA- 2002)

Client : Executive Engineer, Dasarahalli Zone, BBMP, Bangalore.

Agency : Sri. M. Yogesh (M/s. Professional global infrastructure privited limited), Bangalore.

Name of Work : Restoration of road cut portion done by BWSSB in Abbigere village F Bus stop surrounding area in ward no.12, Shettyhalli sub division , PKG.01 , BBMP, Bangalore.

Date of Testing : 23.11.2019

Material : Stone Dust

Total Wt. of Aggregates in gms 1000

Is Sieve Size in mm	Weight Retained (gm)	Retained Weight in %	Cumulative Retained Weight in %	Cumulative Weight Passing in %	Spec.Limits For Zone-II
10	0	0	0	100	100
4.75	64	6.40	6.40	93.6	90-100
2.36	132	13.20	19.60	80.4	75-100
1.18	141	14.10	33.70	66.3	55-90
600 Micron	232	23.20	56.90	43.1	35-59
300 Micron	206	20.60	77.50	22.5	8-30
150 Micron	154	15.40	92.90	7.1	0-10

The report shall not be reproduced, except in full, without the written approval of the laboratory.
The results indicated above are based on the tests carried out on the samples received in the laboratory.
Any Query regarding the report must be reported within 30days from the date of testing.

For CIVIL QUALITY CONSULTANTS & ENGINEERS

AE/15-12

Authorized Signatory